

SECTION 33 51 13 – NATURAL GAS PIPING**PART 1: GENERAL****1.01**

- A. Do not include a manual bypass around the natural gas regulator.
- B. Avoid 2-1/2, 3-1/2 and 5-inch pipe in natural gas systems.
- C. Valves for use on natural gas shall typically be plug-type, AGA approved and meeting requirements of local gas utility companies. Where ball valves are approved, they must be manufactured as AGA approved.

PART 2: PRODUCTS (NOT USED)**PART 3: EXECUTION (NOT USED)**

END OF SECTION 33 51 13