

**SECTION 23 09 33 – VARIABLE FREQUENCY DRIVES**

**PART 1-GENERAL**

1.01 DESCRIPTION

- A. This specification is to cover a complete Variable Frequency motor Drive (VFD) consisting of a pulse width modulated (PWM) inverter designed for use on a standard NEMA Design B induction motor.
- B. The drive manufacturer shall supply the drive and all necessary controls as herein specified. The manufacturer shall have been engaged in the production of this type of equipment for a minimum of twenty years. VFD's that are manufactured by a third party and "brand labeled" shall not be acceptable.

1.02 QUALITY ASSURANCE

- A. Referenced Standards:
  - 1. Institute of Electrical and Electronic Engineers (IEEE)
    - a) Standard 519-1992, IEEE Guide for Harmonic Content and Control.
  - 2. Underwriters laboratories
    - a) UL508C
  - 3. National Electrical Manufacturer's Association (NEMA)
    - a) ICS 7.0, AC Adjustable Speed Drives
  - 4. IEC 16800 Parts 1 and 2
  - 5. International Building Code 2006
- B. Qualifications:
  - 1. VFDs and options shall be UL listed as a complete assembly. VFD's that require the customer to supply external fuses for the VFD to be UL listed are not acceptable. VFDs with requiring additional branch circuit protection are not acceptable. The base VFD shall be UL listed for 100 KAIC without the need for input fuses.
  - 2. CE Mark – The VFD shall conform to the European Union ElectroMagnetic Compatibility directive, a requirement for CE marking. The VFD shall meet product standard EN 61800-3 for the First Environment restricted level.
  - 3. Acceptable Manufactures
    - Base Bid
    - a) ABB ACH580 VFD with Bluetooth option
    - b) VFDs that are manufactured by a third party and "brand labeled" shall not be acceptable.

1.03 SUBMITTALS

- A. Submittals shall include the following information:
  - 1. Outline dimensions, conduit entry locations and weight.
  - 2. Customer connection and power wiring diagrams.
  - 3. Complete technical product description include a complete list of options provided. Any portions of the specifications not complied with must be clearly indicated or the supplier and contractor shall be liable to provide all components required to meet the specification.

**PART 2 – PRODUCTS**

2.01 VARIABLE FREQUENCY DRIVES

**SECTION 23 09 33 – VARIABLE FREQUENCY DRIVES**

- A. The VFD package as specified herein shall be enclosed in a UL Listed Type enclosure, (NEMA rated enclosures are not acceptable) completely assembled and tested by the manufacturer in an ISO9001 facility.
  - 1. Environmental operating conditions: 0-40C continuous. Altitude 0 to 3300 feet above sea level, up to 95% humidity, non-condensing.
  - 2. Enclosure shall be rated UL type 1 and shall be UL listed as a plenum rated VFD. VFD's without these ratings are not acceptable.
  
- B. All VFDs shall have the following features:
  - 1. All VFDs shall have the same customer interface, including digital display, and keypad, regardless of horsepower rating. The keypad shall be removable, capable of remote mounting and allow for uploading and downloading of parameter settings as an aid for start-up of multiple VFDs.
  - 2. The keypad shall include Hand-Off-Auto selections and manual speed control. There shall be fault reset and "Help" buttons on the keypad. The Help button shall include "on-line" assistance for programming and troubleshooting.
  - 3. There shall be a built-in time clock in the VFD keypad. The clock shall have a battery back up with 10 years minimum life span. The clock shall be used to date and time stamp faults and record operating parameters at the time of fault. If the battery fails, the VFD shall automatically revert to hours of operation since initial power up. The clock shall also be programmable to control start/stop functions, constant speeds, PID parameter sets and output relays. The VFD shall have a digital input that allows an override to the time clock (when in the off mode) for a programmable time frame. There shall be four (4) separate, independent timer functions that have both weekday and weekend settings. Capacitor backup is not acceptable.
  - 4. The VFD shall be capable of both displaying on the VFD panel and communicating to the BMS the KWhrs used, MWhrs, Run Time, Input KWhrs, and Input KWhrs. Additionally, the VFD shall accept the dollars per KWhr for the facility (\$/KWhrs) and use this to display and communicate the Dollars saved from running below full load.
  - 5. The VFD shall be capable of displaying and communicating with BMS the Tons of CO2 saved by not running at full load.
  - 6. The VFD shall be capable of starting into a coasting load (forward or reverse) up to full speed and accelerate or decelerate to setpoint without safety tripping or component damage (flying start).
  - 7. The overload rating of the drive shall be 110% of its normal duty current rating for 1 minute every 10 minutes, 130% overload for 2 seconds. The minimum FLA rating shall meet or exceed the values in the NEC/UL table 430-150 for 4-pole motors.
  - 8. The VFD shall have 5% impedance reactors to reduce the harmonics to the power line and to add protection from AC line transients. The 5% impedance may be from dual (positive and negative DC bus) reactors, or 5% AC line reactors. VFD's with only one DC reactor shall add AC line reactors.
  - 9. The VFD shall provide a programmable proof of flow from c relay output (broken belt / broken coupling). The drive shall be programmable to signal this condition via a keypad warning, relay output and/or over the serial communications bus.

**SECTION 23 09 33 – VARIABLE FREQUENCY DRIVES**

Relay outputs shall include programmable time delays that will allow for drive acceleration from zero speed without signaling a false underload condition.

- D. All VFDs to have the following adjustments:
1. Three (3) programmable critical frequency lockout ranges to prevent the VFD from operating the load continuously at an unstable speed.
  2. Two (2) PID Setpoint controllers shall be standard in the drive, allowing pressure or flow signals to be connected to the VFD, using the microprocessor in the VFD for the closed loop control. The VFD shall have 250 ma of 24 VDC auxiliary power and be capable of loop powering a transmitter supplied by others. There shall be two parameter sets for the first PID that allow the sets to be switched via a digital input, serial communications or from the keypad for night setback, summer/winter setpoints, etc. There shall be an independent, second PID loop that can utilize the second analog input and modulate one of the analog outputs to maintain setpoint of an independent process (ie. valves, dampers, etc.). All setpoints, process variables, etc. to be accessible from the serial communication network.
  3. Two (2) programmable analog inputs shall accept current or voltage signals.
  4. Two (2) programmable analog outputs (0-20ma or 4-20 ma). The outputs may be programmed to output proportional to Frequency, Motor Speed, Output Voltage, Output Current, Motor Torque, Motor Power (kW), DC Bus voltage, Active Reference, and other data.
  5. Six (6) programmable digital inputs.
  6. Three (3) programmable digital Form-C relay outputs. The relays shall include programmable on and off delay times and adjustable hysteresis. The relays shall be rated for maximum switching current 8 amps at 24 VDC and 0.4 A at 250 VAC; Maximum voltage 300 VDC and 250 VAC; continuous current rating 2 amps RMS. Outputs shall be true form C type contacts; open collector outputs are not acceptable.
  7. Run permissive circuit - There shall be a run permissive circuit for damper or valve control. Regardless of the source of a run command (keypad, time-clock control, or serial communications) the VFD shall provide a dry contact closure that will signal the damper to open (VFD motor does not operate). When the damper is fully open, a normally open dry contact (end-switch) shall close. The closed end-switch is wired to a VFD digital input and allows motor operation. Two separate safety interlock inputs shall be provided. When either safety is opened, the motor shall be commanded to coast to stop, and the damper shall be commanded to close.
  8. Two independently adjustable accel and decel ramps with 1 – 1800 seconds adjustable time ramps.
  9. The VFD shall include a motor flux optimization circuit that will automatically reduce applied motor voltage to the motor to optimize energy consumption and audible motor noise.
  10. The AFD shall have an energy optimization routine that automatically adjusts the energy provided to the motor; continually matching to the specific load and speed of the attached mechanical system. VFDs that only provide generalized Linear or Squared Volts / Hz operation shall not be allowed.
  11. The VFD shall include a carrier frequency control circuit that reduces the carrier frequency based on actual VFD temperature that allows higher carrier frequency without derating the VFD or operating at high carrier frequency only at low speeds.
  12. The VFD shall include password protection against parameter changes.

**SECTION 23 09 33 – VARIABLE FREQUENCY DRIVES**

- E. The Keypad shall include a backlit LCD display. The display shall be in complete English words for programming and fault diagnostics (LED and alpha-numeric codes are not acceptable). All VFD faults shall be displayed in English words.
- F. All applicable operating values shall be capable of being displayed in engineering (user) units. A minimum of three operating values from the list below shall be capable of being displayed at all times. The display shall be in complete English words (alpha-numeric codes are not acceptable):
  - Output Frequency
  - Motor Speed (RPM, %, or Engineering units)
  - Motor Current
  - Drive Temperature
  - DC Bus Voltage
  - Output Voltage
- G. The VFD shall include a fireman’s override input. Upon receipt of a contact closure from the fireman’s control station, the VFD shall operate in one of two modes: 1) Operate at a programmed predetermined fixed speed or operate in a specific fireman’s override PID algorithm that automatically adjusts motor speed based on override setpoint and feedback . The mode shall override all other inputs (analog/digital, serial communication, and all keypad commands), except customer defined safety run interlock, and force the motor to run in one of the two modes above. “Override Mode” shall be displayed on the keypad. Upon removal of the override signal, the VFD shall resume normal operation.
- H. Serial Communications
  - 1. The VFD shall have an RS-485 port as standard. The standard protocols shall be Modbus, BACnet, Johnson Controls N2 bus, and Siemens Building Technologies FLN. Each individual drive shall have the protocol in the base VFD. The use of third party gateways and multiplexers is not acceptable. All protocols shall be “certified” by the governing authority (ie BTL Listing for BacNet). Use of non-certified protocols is not allowed.
  - 2. The BACnet connection shall be an RS485, MSTP interface operating at 9.6, 19.2, 38.4, or 76.8 Kbps. The connection shall be tested by the BACnet Testing Labs (BTL) and be BTL Listed. The BACnet interface shall conform to the BACnet standard device type of an Applications Specific Controller (B-ASC). The interface shall support all BIBBs defined by the BACnet standard profile for a B-ASC including, but not limited to:
    - a. Data Sharing – Read Property – B.
    - b. Data Sharing – Write Property – B.
    - c. Device Management – Dynamic Device Binding (Who-Is; I-AM).
    - d. Device Management – Dynamic Object Binding (Who-Has; I-Have).
    - e. Device Management – Communication Control – B.
  - 3. Serial communication capabilities shall include, but not be limited to; run-stop control, speed set adjustment, proportional/integral/derivative PID control adjustments, current limit, accel/decel time adjustments, and lock and unlock the keypad. The drive shall have the capability of allowing the DDC to monitor feedback such as process variable feedback, output speed / frequency, current (in amps), % torque, power (kW), kilowatt hours (resettable), operating hours (resettable), and drive temperature. The DDC shall also be capable of monitoring the VFD relay output status, digital input status, and all analog input and analog output values. “Pass thru I/O” All diagnostic warning and fault information shall

SECTION 23 09 33 – VARIABLE FREQUENCY DRIVES

be transmitted over the serial communications bus. Remote VFD fault reset shall be possible.

- I. EMI / RFI filters. All VFD's shall include EMI/RFI filters. The VFD shall comply standard EN 61800-3 for the First Environment, restricted level with up to 100' of motor cables. No Exceptions. Certified test lab test reports shall be provided with the submittals
- J. All VFD's through 60HP shall be protected from input and output power mis-wiring. The VFD shall sense this condition and display an alarm on the keypad. The VFD shall not be damaged by this condition.
- K. OPTIONAL FEATURES – Optional features to be furnished and mounted by the drive manufacturer. All optional features shall be UL Listed by the drive manufacturer as a complete assembly and carry a UL508 label. The bypass enclosure door and VFD enclosure must be interlocked such that input power is turned off before either enclosure can be opened. The VFD and Bypass as a package shall have a UL listed short circuit rating of 100,000 amps and shall be indicated on the data label.
  - 1. A complete factory wired and tested bypass system consisting of an output contactor and bypass contactor, service (isolation) switch and VFD input fuses are required. Bypass designs, which have no VFD only fuses, or that incorporate fuses common to both the VFD and the bypass will not be accepted (Redundant VFD with no bypass on air handlers. Bypasses required on all other VFDS)
  - 2. Door interlocked, padlockable circuit breaker that will disconnect all input power from the drive and all internally mounted options.
- L. BYPASS CONTROLLER
- M. The following operators shall be provided:
  - a. Bypass Hand-Off-Auto
  - b. Drive mode selector and light
  - c. Bypass mode selector and light
  - d. Bypass fault reset
  - e. Bypass LDC display, 2 lines, for programming and status / fault / warning indications
  - 1. Motor protection from single phase power conditions- The Bypass system must be able to detect a single phase input power condition while running in bypass, disengage the motor in a controlled fashion, and give a single phase input power indication. Bypass systems not incorporating single phase protection in Bypass mode are not acceptable.
  - 2. The system (VFD and Bypass) tolerated voltage window shall allow the system to operate from a line of +30% , -35% nominal voltage as a minimum. The system shall incorporate circuitry that will allow the drive or bypass contactor to remain “sealed in” over this voltage tolerance at a minimum.
  - 3. The Bypass system shall NOT depend on the VFD for bypass operation. The bypass shall be completely functional in both Hand and Automatic modes even if the VFD has been removed from the enclosure for repair / replacement.
  - 4. Serial communications – the bypass and VFD shall be capable of being monitored and / or controlled via serial communications. Provide communications protocols for ModBus; Johnson Controls N2; Siemens Building Technologies FLN (P1) and BacNet.

SECTION 23 09 33 – VARIABLE FREQUENCY DRIVES

5. BACnet Serial communication bypass capabilities shall include, but not be limited to; bypass run-stop control; the ability to force the unit to bypass; and the ability to lock and unlock the keypad. The bypass shall have the capability of allowing the DDC to monitor feedback such as, bypass current (in amps), bypass kilowatt hours (resettable), bypass operating hours (resettable), and bypass logic board temperature. The DDC shall also be capable of monitoring the bypass relays output status, and all digital input status. "Pass thru I/O" All bypass diagnostic warning and fault information shall be transmitted over the serial communications bus. Remote bypass fault reset shall be possible. The following additional bypass status indications and settings shall be transmitted over the serial communications bus – keypad "Hand" or "Auto" selected, and bypass selected. The DDC system shall also be able to monitor if the motor is running under load in both VFD and bypass (proof of flow) in the VFD mode over serial communications or Form C relay output. A minimum of 40 field parameters shall be capable of being monitored in the bypass mode.
6. Run permissive circuit - There shall be a run permissive circuit for damper or valve control. Regardless of the source of a run command (keypad, time-clock control, or serial communications) the VFD and bypass shall provide a dry contact closure that will signal the damper to open (VFD motor does not operate). When the damper is fully open, a normally open dry contact (end-switch) shall close. The closed end-switch is wired to a VFD system input and allows motor operation. Two separate safety interlock inputs shall be provided. When either safety is opened, the motor shall be commanded to coast to stop, and the damper shall be commanded to close.
7. The bypass control shall monitor the status of the VFD and bypass contactors and indicate when there is a welded contactor contact or open contactor coil. This failed contactor operation shall be indicated on the Bypass LCD display as well as over the serial communications protocol.
8. The bypass control shall include a programmable time delay for bypass start and keypad indication that this time delay is in process. This will allow VAV boxes to be driven open before the motor operates at full speed in the bypass mode. The time delay shall be field programmable from 0 – 120 seconds.
9. The bypass control shall be programmable for manual or automatic transfer to bypass. The user shall be able to select via keypad programming which drive faults will generate an automatic transfer to bypass and which faults require a manual transfer to bypass.
10. There shall be an adjustable motor current sensing circuit for the bypass and VFD mode to provide proof of flow indication. The condition shall be indicated on the keypad display, transmitted over the building automation protocol and on a relay output contact closure.
11. The bypass controller shall have six programmable digital inputs, and five programmable form C relay outputs.
12. The relay outputs from the bypass shall be programmable for any of the following indications.
  - a. System started
  - b. System running
  - c. Bypass override enabled
  - d. Drive fault
  - e. Bypass fault
  - f. Bypass H-O-A position
  - g. Motor proof of flow (broken belt)
  - h. Overload
  - i. Bypass selected
  - j. Bypass run

**SECTION 23 09 33 – VARIABLE FREQUENCY DRIVES**

- k. System started (damper opening)
  - l. Bypass alarm
  - m. Over temperature
13. The digital inputs for the system shall accept 24VAC or 24VDC. The bypass shall incorporate internally sourced power supply and not require an external control power source. The bypass power board shall supply 250 ma of 24 VDC for use by others to power external devices.
14. Customer Interlock Terminal Strip – provide a separate terminal strip for connection of freeze, fire, smoke contacts, and external start command. All external safety interlocks shall remain fully functional whether the system is in VFD or Bypass mode. The remote start/stop contact shall operate in VFD and bypass modes. The terminal strip shall allow for independent connection of up to four (4) unique safety inputs.
15. The user shall be able to select the text to be displayed on the keypad when the safety opens. Example text display indications include “Firestat”, “Freezstat”, “Over pressure” and “Low pressure”. The user shall also be able to determine which of the four (4) safety contacts is open over the serial communications connection.
16. Class 10, 20, or 30 (selectable) electronic motor overload protection shall be included.

**PART 3 – EXECUTION**

**12.01 INSTALLATION**

- A. Installation shall be the responsibility of the mechanical contractor. The contractor shall install the drive in accordance with the requirements of the VFD manufacturer’s installation manual.

**12.02 START-UP**

- A. Certified factory start-up shall be provided for each drive by a factory certified service center. A certified start-up form shall be filled out for each drive with a copy provided to the owner, and a copy kept on file at the manufacturer.

**12.03 PRODUCT SUPPORT**

- A. Factory trained application engineering and service personnel that are thoroughly familiar with the VFD products offered shall be locally available at both the specifying and installation locations. A toll free 24/365 technical support line shall be available.
- B. A computer based training CD or 8-hour professionally generated video (VCR format) shall be provided to the owner at the time of project closeout. The training shall include installation, programming and operation of the VFD, bypass and serial communication.
- C. Quarterly training will be provided throughout the lifetime (10 years) of the VFD at no charge to Texas State University.

**SECTION 23 09 33 – VARIABLE FREQUENCY DRIVES**

12.04 WARRANTY

- A. Warranty shall be 72 months from the date of startup. The warranty shall include all parts, labor, travel time and expenses. This warranty shall be provided with the agreed upon complete care preventative maintenance program described below

12.05 PREVENTATIVE MAINTENANCE

- A. The 72 month warranty above shall be provided with two preventative maintenance visits that include repairs, parts, labor and travel costs, and new or repaired drives (when determined necessary by ABB quality standards).
- B. PM service will be provided at year 3 and one month prior to warranty expiration at year 6.
- C. A detailed service report will be provided which includes recommendations for future actions. This report will be forwarded to the maintenance and facilities group.
- D. PM service will provide
  - a. Qualified and certified drive specialists to perform maintenance work with genuine spare parts
  - b. Visual inspection of the electrical drive and its environmental conditions
  - c. Inspection of the connections, the ribbon cables and fiber optic cables
  - d. Functional inspection of the fan(s) and the cooling system
  - e. ESD protected cleaning of the drive
  - f. Inspection of the emergency stop and the prevention of unexpected start-up circuit if applicable
  - g. Inspection of the fault logger
  - h. Inspection and storage of the parameters
  - i. Functional testing of the drive under normal conditions (planned with the air conditioning shop)
  - j. Basic measurements with supply voltage
  - k. Inspection of the drive spare part inventory
  - l. Reforming of the spare module capacitors

**End of Section**