

2015 Annual Drinking Water Quality Report

(Consumer Confidence Report)

TEXAS STATE UNIVERSITY-FREEMAN

RANCH PWS# 1050163

Phone No: 512-245-8629

SPECIAL NOTICE Required language for ALL community public water supplies:

You may be more vulnerable than the general population to certain microbial contaminants, such as *Cryptosporidium*, in drinking water. Infants, some elderly or immunocompromised persons such as those undergoing chemotherapy for cancer; those who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care provider. Additional guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* are available from the Safe Drinking Water Hotline at (800) 426-4791.

Our Drinking Water Meets or Exceeds All Federal (EPA) Drinking Water Requirements

This report is a summary of the quality of the water we provide our customers. The analysis was made by using the data from the most recent U.S. Environmental Protection Agency (EPA) required tests and is presented in the attached pages. We hope this information helps you become more knowledgeable about what's in your drinking water.

WATER SOURCES: The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals, and in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water before treatment include: microbes, inorganic contaminants, pesticides, herbicides, radioactive contaminants, and organic chemical contaminants.

En Español

Este reporte incluye información importante sobre el agua para tomar. Para asistencia en español favor de llamar al telefono(512) 245- 3848 - para hablar con una persona bilingüe en español.

To learn about future public meetings (concerning your drinking water), or to request to schedule one, please call us.

Public Participation Opportunities

Date: None Scheduled

Time:

Location:

Phone No: 512-245-8629

Where do we get our drinking water?

Our drinking water is obtained from GROUND water sources. It comes from the following Lake/River/Reservoir/**Aquifer: EDWARDS SOUTH BFZ**. A Source Water Susceptibility Assessment for your drinking water source(s) is currently being updated by the Texas Commission on Environmental Quality and will be provided to us this year. The report will describe the susceptibility and types of constituents that may come into contact with your drinking water source based on human activities and natural conditions. The information contained in the assessment will allow us to focus our source water protection strategies. Some of this source water assessment information will be available later this year on Texas Drinking Water Watch at <http://dww.tceq.state.tx.us/DWW/>. For more information on source water assessments and protection efforts at our system, please contact us.

ALL drinking water may contain contaminants.

When drinking water meets federal standards there may not be any health based benefits to purchasing bottled water or point of use devices. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (1-800-426-4791).

Secondary Constituents

Many constituents (such as calcium, sodium, or iron) which are often found in drinking water, can cause taste, color, and odor problems. The taste and odor constituents are called secondary constituents and are regulated by the State of

Texas, not the EPA. These constituents are not causes for health concern. Therefore, secondary's are not required to be reported in this document but they may greatly affect the appearance and taste of your water.

About The Following Pages

The pages that follow list all of the federally regulated or monitored contaminants which have been found in your drinking water. The U.S. EPA requires water systems to test for up to 97 contaminants.

DEFINITIONS

Maximum Contaminant Level (MCL)

The highest permissible level of a contaminant in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG)

The level of a contaminant in drinking water below which there is no known or expected health risk. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL)

The highest level of disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG)

The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

Treatment Technique (TT)

A required process intended to reduce the level of a contaminant in drinking water.

Action Level (AL)

The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

ABBREVIATIONS

NTU - Nephelometric Turbidity Units
MFL - million fibers per liter (a measure of asbestos)
pCi/L - picocuries per liter (a measure of radioactivity)
ppm - parts per million, or milligrams per liter(mg/L)
ppb - parts per billion, or micrograms per liter(µg/L)
ppt - parts per trillion, or nanograms per liter
ppq -parts per quadrillion, or picograms per liter

Inorganic Contaminants

Year or Range	Contaminant	Average Level	Minimum Level	Maximum Level	MCL	MCLG	Unit of Measure	Source of Contaminant
2015	Nitrate [measured as Nitrogen]	.0325	.03	.04	10	10	ppm	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits.

Organic Contaminants NOT TESTED OR REPORTED, OR NONE DETECTED

Maximum Residual Disinfectant Level

Systems must complete and submit disinfection data on the Disinfection Level Quarterly Operating Report (DLQOR). On the CCR report, the system must provide disinfectant type minimum, maximum and average levels.

Year	Disinfectant	Average Level	Minimum Level	Maximum Level	MCL	MCLG	Unit of Measure	Source of Disinfectant
2014	Chlorine Residual, Free	0.7	0.5	1.0	4	4	ppm	Disinfectant used to control microbes.

Disinfection Byproducts

Year	Contaminants	Average Level	Minimum Level	Maximum Level	MCL	Unit of Measure	Source of Disinfectant

Unregulated Initial Distribution System Evaluation for Disinfection Byproducts WAIVED OR NOT YET SAMPLED

Unregulated Contaminants NOT REPORTED OR NONE DETECTED

Unregulated Contaminant Monitoring Rule 2 (UCMR2)

Unregulated contaminants are those for which EPA has not established drinking water standards. The purpose of unregulated contaminant monitoring is to assist EPA in determining the occurrence of unregulated contaminants in drinking water and whether future regulation is warranted. Any unregulated contaminants detected are reported in the following table. For additional information and data visit <http://www.epa.gov/safewater/ucmr/ucmr2/index.html>, or call the Safe Drinking Water Hotline at (800)426-4791

Year (Range)	Contaminants	Average Level	Minimum Level	Maximum Level	Unit of Measure	Source of Contaminant

Lead and Copper

Year	Contaminant	The 90 th Percentile	Number of Sites Exceeding Action Level	Action Level	Unit of Measure	Source of Disinfectant
	Lead		0	15	ppb	Corrosion of household plumbing systems; erosion of natural deposits
2015	Copper	.0027	0	1.3	ppm	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives

Recommended Additional Health Information for Lead

“if present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead

in drinking water is primarily from materials and components associated with service lines and home plumbing. This water supply is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline at <http://www.epa.gov/safewater/lead>.”

Turbidity NOT REQUIRED

Regulated Contaminants Detected

Contaminants, Disinfectants and Disinfection By-Products	Collection Date	Highest Level Detected	Range of Level Detected	Maximum Contaminant Level Goal	Maximum Contaminant Level	Units	Violation	Likely Source Of Contamination
Coliform Bacteria	Monthly 2015	0	0	0	1 Positive Monthly		N	Naturally Present in the environment
Total Trihalomethanes (TTHM)				No goal for the total	80	ppb	N	By-product of drinking water disinfection
Barium				2	2	ppm	N	Discharge of drilling waste; Discharge from metal refineries; Erosion from natural deposits
Fluoride	9/10/2015	1.36		4	4	ppm	N	Erosion from natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Nitrate [measured as Nitrogen]	9/10/2015	.04	.035	10	10	ppm	N	Runoff from fertilizer use; Leaching from septic tanks; sewage; Erosion from natural deposits.
Gross Alpha Compliance				0	15	pCi/L	N	Erosion from natural deposits.

Violations Table

E. Coli: Fecal coliforms and E. Coli are bacteria whose presence indicates that the water may be contaminated with human or animal waste. Microbes in these wastes can cause short term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a special health risk for infants, young children, and people with severely compromised immune systems.			
Violation Type	Violation Begin	Violation End	Violation Explanation

Public Notification Rule

The Public Notification Rule helps to ensure that consumers will always know if there is a problem with their drinking water. These notices immediately alert consumers if there is a serious problem with their drinking water (e.g., a boil water emergency).

Violation Type	Violation Begin	Violation End	Violation Explanation

Secondary and Other Not Regulated Constituents

(No associated adverse health effects)

Year or Range	Constituent	Average Level	Minimum Level	Maximum Level	Secondary Limit	Unit of Measure	Source of Constituent
	Bicarbonate				NA	ppm	Corrosion of carbonate rocks such as limestone.
	Calcium				NA	ppm	Abundant naturally occurring element.
2015	Chloride	46	46	46	300	ppm	Abundant naturally occurring element; used in water purification; byproduct of oil field activity
2015	Copper	.0027	0	1.3	NA	ppm	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives.
2015	Magnesium	>.001	0	.05	NA	ppm	Abundant naturally occurring element
	Nickel				NA	Ppm	Erosion of natural deposits
	pH				>7.0	units	Measure of corrosively of water
	Sodium				NA	ppm	Erosion of natural deposits; byproduct of oil field activity
2015	Sulfate	608	608	608	300	ppm	Naturally occurring; common industrial byproduct; byproduct of oil field activity
	Total Alkalinity as CaCO ₃				NA	ppm	Naturally occurring soluble mineral salts.
2015	Total Dissolved Solids	1190	1190	1190	1000	ppm	Total dissolved mineral constituents in water
	Total Hardness as CaCO ₃				NA	ppm	Naturally occurring calcium
2015	Zinc	.0407	.0407	.0407	5	ppm	Moderately abundant naturally occurring element used in the metal industry

Page Intentionally Left Blank